

| Self Contained One Meter Assemblies - 120/240 Vac 1 Phase 3 wire, service 100 Amperes | | | |
|---|---------------|--------------------|--|
| Manufacture | Ampere Rating | Catalog Number | Description |
| Milbank | 100 | U1770-YL-TG-KK-BLG | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| Durham | 125 | 1003880A | Ringless design device for OH service, must be supplied with a 5 - jaw horn bypass meter socket |
| Eaton / Cutler-Hammer | 125 | 1003880A-CH | Ringless design device for OH service, must be supplied with a 5 - jaw horn bypass meter socket |
| Square D | 125 | 1003880A-SQD | Ringless design device for OH service, must be supplied with a 5 - jaw horn bypass meter socket |
| Midwest Electric Products | 125 | 1003880A-MEP | Ringless design device for OH service, must be supplied with a 5 - jaw horn bypass meter socket |
| Siemens | 135 | SUAT111-0MSP | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | | SUAT111-0PV | |
| | | SUAT111-XQA | |
| Talon | 135 | UAT111-0MSP | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | | UAT111-XMBL | |
| | | UAT111-XQA | |

| Self Contained One Meter Assemblies - 120/240 Vac 1 Phase 3 wire, service 200 Amperes or less | | | |
|---|---------------|---------------------|--|
| Manufacture | Ampere Rating | Catalog Number | Description |
| Milbank | 200 | U3042-XL-QG-BLG-LIS | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| | 200 | U8173-XL-KK-BLG | Ringless design device for UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | U3599-O-KK-BLG | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | U8729-DL-KK-BLG | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| Durham | 200 | 1003879A | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1004967B | Ringless design device for UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1003878A | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1005763 | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |

| | | | |
|---------------------------|-----|-----------------|--|
| Eaton / Cutler-Hammer | 200 | 1003879A-CH | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1004967B-CH | Ringless design device for UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1003878A-CH | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1005763-CH | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| | 200 | UG-H4213C-CC-CH | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| | 200 | UG-E4213C-CC-CH | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| Square D | 200 | 1003879A-SQD | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1004967B-SQD | Ringless design device for UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1003878A-SQD | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1005763-SQD | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| Midwest Electric Products | 200 | 1003879A-MEP | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1004967B-MEP | Ringless design device for UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1003878A-MEP | Ringless design device for OH/UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | 1005763-MEP | Ringless design device for OH/UG service, must be supplied with a 5 - jaw lever bypass meter socket |
| Siemens | 200 | SUAT317-0FP | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | SUAT417-XFP | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | SUAS877-PPGP | Ringless design sidewire device for UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | | SUAS817-PFP | |
| | 200 | S40405-015F | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |
| Talon | 200 | UAT317-0FP | Ringless design device for OH service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | UAT417-XMBL | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | UAT417-XFP | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket |
| | 200 | UAS877-PPGP | Ringless design sidewire device for UG service, must be supplied with a 5 - jaw horn bypass meter socket |
| | | UAS817-PFP | |
| | 200 | 40405-02OC | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |

INTERNAL

| | | | |
|--------|-----|----------|--|
| Murray | 200 | RH173CRF | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |
|--------|-----|----------|--|

| Self Contained One Meter Assemblies - 120/240 Vac 1 Phase 3 wire, 320 Ampere service ONLY. | | | |
|---|---------------|----------------|---|
| Manufacture | Ampere Rating | Catalog Number | Description |
| Siemens | 320 | S48105-83BU | Ringless design sidewire device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |
| Talon | 320 | 48105-83BU | Ringless design sidewire device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |
| Murray | 320 | RK178C-LI | Ringless design sidewire device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |
| Milbank | 320 | U3885-X-BLG | Ringless design sidewire device for UG service only, must be supplied with a 5 - jaw lever bypass meter socket |

| Self Contained Multiple Position Meter Assemblies - 120/240 Vac 1 Phase 3 wire service | | | |
|--|------------------|----------------|---|
| Manufacture | Ampere Rating | Catalog Number | Description |
| Durham | 100 Per Position | 1004399A | Two position ringless design device with end feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Eaton / Cutler-Hammer | 100 Per Position | 1004399A-CH | Two position ringless design device with end feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Square D | 100 Per Position | 1004399A-SQD | Two position ringless design device with end feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Midwest Electric Products | 100 Per Position | 1004399A-MEP | Two position ringless design device with end feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Siemens | 100 Per Position | SUA2311-XBBU | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| | 100 Per Position | SUA3311-XBBU | Three position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| | 100 Per Position | SUA4311-XBBU | Four position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Talon | 100 Per Position | UA2311-XBBU | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| | 100 Per Position | UA3311-XBBU | Three position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| | 100 Per Position | UA4311-XBBU | Four position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Durham | 200 Per Position | 1004418A | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |

INTERNAL

| | | | |
|---------------------------|------------------|----------------|---|
| Eaton / Cutler-Hammer | 200 Per Position | 1004418A-CH | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Square D | 200 Per Position | 1004418A-SQD | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Midwest Electric Products | 200 Per Position | 1004418A-MEP | Two position ringless design device with center feed for OH/UG service, must be supplied with 5 - jaw horn bypass meter sockets |
| Milbank | 200 Per Position | U1252-X-KK-BLG | Two position ringless design device, must be supplied with 5 - jaw horn bypass meter sockets |

| Self Contained Combination Service Entrance Assemblies - 120/240 Vac 1 Phase, 3 wire, service. | | | |
|--|---------------|----------------------|---|
| Manufacture | Ampere Rating | Catalog Number | Description |
| Square D | 100 | RC816F100CH | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket. Requires 5th Jaw kit, catalog number 5J. |
| | 125 | RC816F125CH | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket. Requires 5th Jaw kit, catalog number 5J. |
| | 150 | RC816F150CH | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket. Requires 5th Jaw kit, catalog number 5J. |
| | 200 | RC816F200CH | Ringless design device for OH/UG service only, must be supplied with a 5 - jaw horn bypass meter socket. Requires 5th Jaw kit, catalog number 5J. |
| Milbank | 200 | U5880-XL-200-5T9-BLG | Ringless design sidewire device for OH/UG service only, must be supplied with a 5 - jaw lever bypass meter socket |

INTERNAL