

SPLIT AND PACKAGED AIR CONDITIONERS (AIR COOLED ONLY)

Equipment Type	Cooling Capacity*		Heating Section Type	Subcategory or Rating Condition	Tier I	
	Tons	Btu/h			Minimum Efficiency*	Incentive (\$/ton)
Air Conditioners, Air Cooled	<5.4	<65,000	All	Split System	13.1 SEER / 13.1 EER	\$25
				Single Package	14.1 SEER / 14.1 EER	
	>=5.4 to <11.25	>=65,000 to <135,000	Electric Resistance (or None)	Split System and Single Package	12.9 IEER/ 11.3 EER	
				All Other	12.7 IEER/ 11.1 EER	
	>=11.25 to <20	>=135,000 to <240,000	Electric Resistance (or None)	Split System and Single Package	12.5 IEER/ 11.1 EER	
				All Other	12.3 IEER/ 10.9 EER	
	>=20 to <63	>=240,000 to <760,000	Electric Resistance (or None)	Split System and Single Package	11.7 IEER/ 10.1 EER	
				All Other	11.5 IEER/ 9.9 EER	
	>=63	>=760,000	Electric Resistance (or None)	Split System and Single Package	11.3 IEER/ 9.8 EER	
				All Other	11.1 IEER/ 9.6 EER	

* Proposed equipment ratings should be per AHRI

HEAT PUMPS, AIR SOURCE (AIR COOLED ONLY)

Equipment Type	Cooling Capacity*		Heating Section Type	Subcategory or Rating Condition	Tier I	
	Tons	Btu/h			Minimum Efficiency*	Incentive (\$/ton)
Heat Pumps, Air Cooled	<5.4	<65,000	All	Split System	14.1 SEER / 14.1 EER	\$25
				Single Package		
	>=5.4 to <11.25	>=65,000 to <135,000	Electric Resistance (or None)	Split System and Single Package	12.1 IEER/ 11.1 EER	
				All Other	11.9 IEER/ 10.9 EER	
	>=11.25 to <20	>=135,000 to <240,000	Electric Resistance (or None)	Split System and Single Package	11.7 IEER/ 10.7 EER	
				All Other	11.5 IEER/ 10.5 EER	
	>=20	>=240,000	Electric Resistance (or None)	Split System and Single Package	10.7 IEER/ 9.6 EER	
				All Other	9.5 IEER/ 9.4 EER	

* Proposed equipment ratings should be per AHRI

ELIGIBILITY REQUIREMENTS: Qualifying split systems must have both a new condenser and a new coil that meets AHRI specifications and where the matched system performance (condenser and coil) meets or exceeds the minimum SEER/EER outlined in the tables below. Proposed equipment ratings shall be taken from the Air Conditioning, Heating and Refrigeration Institute (AHRI) Certification Directory (ref. www.ahridirectory.org). All projects must pass O&R's cost-effectiveness screening to be eligible for rebates.